



GENERAL NOTES

1. #4 REBAR DOWELS, 6" MINIMUM DEPTH INTO EXISTING OR NEW SIDEWALK. DO NOT DOWEL PRIVATE IMPROVEMENTS INTO PUBLIC IMPROVEMENTS.
2. 4" MINIMUM CLASS 2 A.B. COMPACTED TO 90%
3. 1/2" DEEP CONTRACTION JOINTS AT 20', 1/4" DEEP CONTRACTION JOINTS AT 10'
SIDEWALK SHALL BE SCORED TO MATCH CONTIGUOUS EXISTING SIDEWALK
4. ALL CONCRETE SHALL BE 6 SACK 3/4" WITH ONE POUND OF LAMP BLACK PER CUBIC YARD
5. ASPHALT TO BE HOT MIX ASPHALT 1/2" FINE

CITY OF BELMONT
DEPARTMENT OF PUBLIC WORKS
GURB, GUTTER
AND SIDEWALK

DWG No. _____

APPROVED
JAN 2013 NOT TO SCALE